

8.2.1.6. Clearances for a Class 4 or 5 Sewage System

Table 8.2.1.6.A.

Minimum Clearances for Treatment Units

Item	Column 1 Object	Column 2 Minimum Clearance, m
1	Structure	1.5 (5 ft)
2	Well	15 (50 ft)
3	Lake	15 (50 ft)
4	Pond	15 (50 ft)
5	Reservoir	15 (50 ft)
6	River	15 (50 ft)
7	Spring	15 (50 ft)
8	Stream	15 (50 ft)
9	Property Line	3 (10 ft)

Table 8.2.1.6.B.

Minimum Clearances for Distribution Piping

Item	Column 1 Object	Column 2 Minimum Clearance, m
1	Structure	5 (16 ft)
2	Well with a watertight casing to a depth of at least 6 m	15 (50 ft)
3	Any other well	30 (100 ft)
4	Lake	15 (50 ft)
5	Pond	15 (50 ft)
6	Reservoir	15 (50 ft)
7	River	15 (50 ft)
8	Spring not used as a source of potable water	15 (50 ft)
9	Stream	15 (50 ft)
10	Property Line	3 (10 ft)

The distances set out in Column 2 of Table 8.2.1.6.B. shall be increased by twice the height that the *leaching bed* is raised above the original grade.

Table 8.2.1.6.C

Minimum Clearances for Holding Tanks

Item	Column 1 Object	Column 2 Minimum Clearance, m
1	Structure	1.5 (5 ft)
2	Well with a watertight casing to a depth of at least 6 m	15 (50 ft)
3	Any other well	15 (50 ft)
4	Spring	15 (50 ft)
5	Property Line	3 (10 ft)