

# Fire Protection Survey Services™

P.O. Box 170  
Longford Mills, Ontario, Canada, L0K 1L0  
Telephone: (705) 689-6183 Fax: (208) 474-3520  
E-mail: [firepss@bell.net](mailto:firepss@bell.net) Website: [www.fpss.ca](http://www.fpss.ca)

## Fire Department Water Tanker Shuttle Accreditation

Presented To: Township of Stone Mills

### ACCREDITED FIRE STATIONS

F.S.#1 Yarker (6)

F.S.#2 Enterprise (6)

F.S.#3 Newburgh (6)

F.S.#4 Tamworth (6)

(\*)=Commercial / Industrial Fire Protection Classification

Date Test Passed: November 20, 2015

Flow Achieved: 615 I.G.P.M. 2790 LITERS/MIN.

Two (2) Hour Test Time



Signed: Peter J. Rose ~

Peter J. Rose, C.E.T., F.P.T.  
Senior Partner  
Senior Fire Protection Specialist  
Senior Loss Control Specialist

This Certificate Expires on December 01, 2020